

# CATTARAUGUS COUNTY

## DEPARTMENT OF PUBLIC WORKS

### ADDENDUM NO. 1

FOR  
THE REPLACEMENT OF

LEON BRIDGE No. 35

OVER CONEWANGO CREEK  
SMITH ROAD INTERSECTION AND FROG VALLEY ROAD

**ADDENDUM DATE: 15 June 2017**

---

The following are responses to questions the County has received:

1. The permanent steel sheet piles are NOT to be galvanized.
2. The underdrain material, underdrain pipe, concrete and beams shown in Section A-A of Sheet 6 are all to be done by the County and are not included in the items or in the contract.

The following are changes that have been made to the plans:

1. Sheet 7 has been replaced, see attached. The reference to an 8"x8"x1" Cap Angle on both abutment elevation views have been replaced with a reference to a  $\frac{3}{4}$ " Bearing Plate.

---

**ALL BIDDERS MUST RETURN THIS ADDENDUM WITH THE BID AND RECORD THIS  
ADDENDUM IN SECTION B ON SHEET B-2 IN THE BID PROPOSAL BOOK.**

---

**IN ADDITION, PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM 1 IMMEDIATELY BY  
PROVIDING THE INFORMATION BELOW AND FAXING THIS SHEET TO:**

Cattaraugus County  
Department of Public Works  
(716) 938-2754

Company Name: \_\_\_\_\_ Signed: \_\_\_\_\_

Date: \_\_\_\_\_ Printed Name of Signatory: \_\_\_\_\_

